





# PRODUCT CERTIFICATE

**CERTIFICATE NO.: CQC2003010305040873**

**NAME AND ADDRESS OF THE APPLICANT**

Delixi Group Co., Ltd.  
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Delixi Group Co., Ltd.  
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

Delixi Group Co., Ltd. (V034623)  
Unit 3 Electrical Appliance City, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Knife-disconnector

H□□-200、H□□-100、H□□-63 Ue: AC400V/690V/1140V; Ie: 63A、100A、200A; Ui: 1140V; Uimp: 12kV; Ith: 200A(H□□-200)、100A(H□□-100、H□□-63); Icw: 10kA/1s(200A)、5kA/1s(100A、63A); Utilization Category: AC-20A; Poles: 2P、3P、4P; Auxiliary contacts: 1NO1NC; Ith: 6A; AC-15: Ue/Ie: AC380V/1A

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.3-2017

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

**This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .**

**Valid from:** Sep.02,2020

**Valid until:** Apr.12,2025

**The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

**President:**

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0371206



# 产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2003010305040873

纸号: 371206

型号的解释:

II	□	□	-	□	/	□	□	□	□	□
(1)	(2)	(3)		(4)	(5)	(6)	(7)	(8)		

- (1) 刀形隔离器
- (2) “D”表示单投,“S”表示双投
- (3) 设计代号:“11”表示中央操作手柄式;“11F”表示中央手柄操作防误式;“12”表示侧方正面杠杆操作机构式;“13”表示中央正面杠杆操作机构式;“13BX”表示中央正面旋转操作机构式;“13iBX”表示“13BX”的派生型号;“14”表示侧方操作手柄式
- (4) 额定工作电流
- (5) 极数,“2”表示2极,“3”表示3极,“4”表示4极
- (6) “11”、“11F”系列:“8”表示板前接线,“9”表示板后接线;其他系列:“0”表示不带灭弧室,“1”表示带灭弧室
- (7) 对于“11”系列:“B”表示保护型,带保护罩;无表示普通型,不带保护罩
- (8) “1”表示带一副辅助触头,“0”表示不带辅助,可省略;对于“11F”:“1”表示带辅助触头,有防止误操作联锁机构;“0”表示不带辅助触头,无防止误操作联锁机构

注:此附录与证书同时使用时有效。

主任: 陆梅



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>