



产品认证证书

证书编号: CQC2003010305040942

申请人名称及地址

德力西集团有限公司
浙江省乐清市柳市镇柳青路1号(德力西大厦)

制造商名称及地址

德力西集团有限公司
浙江省乐清市柳市镇柳青路1号(德力西大厦)

生产企业名称及地址

德力西集团有限公司(V034623)
浙江省乐清市柳市镇电器城3单元

产品名称和系列、规格、型号

刀形隔离器

H□□-1000、H□□-800 Ue: AC400V/690V/1140V; Ie: 1000A、800A; Ui: 1140V; Uimp: 12kV;
Ith: 1000A; Icw: 30kA/1s; 使用类别: AC-20A; 极数: 3P、4P; 配用的辅助触头: 1NO1NC;
Ith: 6A; AC-15: Ue/Ie: AC400V/1A

产品标准和技术要求

GB/T14048.3-2017

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年09月02日 有效期至: 2025年04月12日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: _____

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0371209



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2003010305040942

NAME AND ADDRESS OF THE APPLICANT

Delixi Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Delixi Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Delixi Group Co., Ltd. (V034623)
Unit 3 Electrical Appliance City, Liushi Town, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Knife-disconnector

H□□-1000、H□□-800 Ue: AC400V/690V/1140V; Ie: 1000A、800A; Ui: 1140V; Uimp: 12kV; Ith: 1000A; Icw: 30kA/1s; Utilization Category: AC-20A; Poles: 3P、4P; Auxiliary contacts: 1NO1NC; Ith: 6A; AC-15: Ue/Ie: AC400V/1A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Sep.02,2020

Valid until: Apr.12,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

c 0371209



产品认证证书

第 1 页 共 1 页

附 录

证书编号: CQC2003010305040942

纸 号: 371209

型号的解释:

H	□	□	-	□	/	□	□	□	□
(1)	(2)	(3)		(4)	(5)	(6)	(7)	(8)	

- (1) 刀形隔离器
- (2) “D”表示单投,“S”表示双投
- (3) 设计代号:“11”表示中央操作手柄式;“11F”表示中央手柄操作防误式;“12”表示侧方正面杠杆操作机构式;“13”表示中央正面杠杆操作机构式;“13BX”表示中央正面旋转操作机构式;“13iBX”表示“13BX”的派生型号;“14”表示侧方操作手柄式
- (4) 额定工作电流
- (5) 极数,“3”表示3极,“4”表示4极
- (6) “11”、“11F”系列:“8”表示板前接线,“9”表示板后接线;其他系列:“0”表示不带灭弧室,“1”表示带灭弧室
- (7) 对于“11”系列:“B”表示保护型,带保护罩;无表示普通型,不带保护罩
- (8) “1”表示带一副辅助触头,“0”表示不带辅助,可省略;对于“11F”：“1”表示带辅助触头,有防止误操作联锁机构;“0”表示不带辅助触头,无防止误操作联锁机构

注:此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>