



# 产品认证证书

证书编号: CQC2005010302169854

## 申请人名称及地址

德力西集团有限公司  
浙江省乐清市柳市镇柳青路1号(德力西大厦)

## 制造商名称及地址

德力西集团有限公司  
浙江省乐清市柳市镇柳青路1号(德力西大厦)

## 生产企业名称及地址

德力西集团有限公司(V034623)  
浙江省乐清市柳市镇电器城3单元

## 产品名称和系列、规格、型号

### 隔离开关

HGL□-630、HGL□-500、HGL□-400、HGL□-315; Ue: AC400V/690V; Ie: 630A、500A、400A、315A; Ui: 1000V;  
Uimp: 12kV; Ith: 630A(HGL□-630、HGL□-500)、400A(HGL□-400、HGL□-315); Icw: 25kA/1s(630A、500A)、20kA/1s(400A、  
315A); Icm(峰值): 52.5kA(630A、500A)、40kA(400A、315A); 使用类别: AC-22B; 极数: 3P、4P.型号解释  
详见附件

## 产品标准和技术要求

GB/T14048.3-2017

## 认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求,特发此证。

发证日期: 2020年09月02日 有效期至: 2025年04月12日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0371210



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2005010302169854

**NAME AND ADDRESS OF THE APPLICANT**

Delixi Group Co., Ltd.  
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Delixi Group Co., Ltd.  
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

Delixi Group Co., Ltd. (V034623)  
Unit 3 Electrical Appliance City, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Switch-disconnector

HGL□-630、HGL□-500、HGL□-400、HGL□-315; Ue: AC400V/690V; Ie: 630A、500A、400A、315A; Ui: 1000V;  
Uimp: 12kV; Ith: 630A(HGL□-630、HGL□-500)、400A(HGL□-400、HGL□-315); Icw: 25kA/1s(630A、500A)、20kA/1s(400A、  
315A); Icm (Peak Value): 52.5kA(630A、500A)、40kA(400A、315A); Utilization Category: AC-22B; Poles: 3P、4P. See  
the Appendix for type explanation

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.3-2017

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

**This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .**

**Valid from:** Sep.02,2020

**Valid until:** Apr.12,2025

**The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

**President:** \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0371210



# 产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2005010302169854

纸 号: 371210

型号的解释:

HGL    □    □ - □ / □    □    □    □  
(1)    (2)    (3)    (4)    (5)    (6)    (7)    (8)

- (1) 隔离开关代号
- (2) 无表示单投, "Z" 表示双投
- (3) 无表示常规型号, "i" 表示派生型号(仅针对单投系列)
- (4) 额定工作电流
- (5) 极数, "3" 表示 3 极, "4" 表示 4 极
- (6) 无表示柜内操作, "J" 表示柜外操作
- (7) 无表示不带观察窗及透明盖, "K" 表示带观察窗, "T" 表示透明盖
- (8) "C" 表示左右型, 无表示上下型 (仅对 HGLZ 系列, 且 2000A 及以上规格仅有上下型)

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>