



# 产品认证证书

证书编号：CQC2005010302169864

## 申请人名称及地址

德力西集团有限公司  
浙江省乐清市柳市镇柳青路1号（德力西大厦）

## 制造商名称及地址

德力西集团有限公司  
浙江省乐清市柳市镇柳青路1号（德力西大厦）

## 生产企业名称及地址

德力西集团有限公司(V034623)  
浙江省乐清市柳市镇电器城3单元

## 产品名称和系列、规格、型号

### 隔离开关

HGL□-1600、HGL□-1250、HGL□-1000、HGL□-800； Ue: AC400V/690V； Ie: 1600A、1250A、1000A、800A； Ui: 1000V； Uimp: 12kV； Ith: 1600A； Icw: 50kA/1s； Icm (峰值)：105kA；  
使用类别：AC-22B； 极数：3P、4P.型号解释详见附件

## 产品标准和技术要求

GB/T14048.3-2017

## 认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求，特发此证。

发证日期：2020年09月02日 有效期至：2025年04月12日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任：\_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0371212



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2005010302169864

**NAME AND ADDRESS OF THE APPLICANT**

Delixi Group Co., Ltd.  
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Delixi Group Co., Ltd.  
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

Delixi Group Co., Ltd. (V034623)  
Unit 3 Electrical Appliance City, Liushi Town, Yueqing, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Switch-disconnector

HGL□-1600、HGL□-1250、HGL□-1000、HGL□-800; Ue: AC400V/690V; Ie: 1600A、1250A、1000A、800A; Ui: 1000V; Uimp: 12kV; Ith: 1600A; Icw: 50kA/1s; Icm (Peak Value): 105kA; Utilization Category: AC-22B; Poles: 3P、4P. See the Appendix for type explanation

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.3-2017

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

**This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .**

**Valid from:** Sep.02,2020

**Valid until:** Apr.12,2025

**The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

**President:** \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0371212



# 产品认证证书

第 1 页 共 1 页

附 录

证书编号: CQC2005010302169864

纸 号: 371212

型号的解释:

<u>HGL</u>	<u>□</u>	<u>□</u> -	<u>□</u> /	<u>□</u>	<u>□</u>	<u>□</u>	<u>□</u>
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)

- (1) 隔离开关代号
- (2) 无表示单投, "Z" 表示双投
- (3) 无表示常规型号, "i" 表示派生型号(仅针对单投系列)
- (4) 额定工作电流
- (5) 极数, "3" 表示 3 极, "4" 表示 4 极
- (6) 无表示柜内操作, "J" 表示柜外操作
- (7) 无表示不带观察窗, "K" 表示带观察窗
- (8) "C" 表示左右型, 无表示上下型 (仅对 HGLZ 系列, 且 2000A 及以上规格仅有上下型)

注: 此附录与证书同时使用时有效。

主任: 陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>