



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE190306006509-A1

**Product** relay

**Applicant** DELIXI Group Co., Ltd.  
No .1 Liuqing Road, Liuzhen, Yueqing City, Zhejiang Province.P.R.China (Delixi Building, Another branch business place :155 zhandong Road, Liushi Town, Yueqing City,Zhejiang Province, P.R.China )

**Type/Model** HXJ3-2,HXJ3-G,HXJ3-5,HXJ3-D;

**Technical data** Ui:380V;Uimp:1.5kV;  
Ith:5A;AC-15:Ue/Ie:AC380V/0.95A,AC240V/1.5A,AC120 V/3A.

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-22D0110-S-A1, the submitted sample(s) of the above item complies with:

**EN60947-5-1:2017**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by themanufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from:** Oct.17,2022

**Valid until:** Oct.16,2025

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

