

产品认证证书

II型自愿认证

证书编号: CQC2003010309095685

发证日期: 2022年01月10日

有效期至: 2031年07月28日

委托人名称 及注册地址	德力西集团有限公司 浙江省乐清市柳市镇柳青路1号(德力西大厦 另设分支机构经营场所 乐清市柳市镇站东路155号)
制造商名称 及注册地址	德力西集团有限公司 浙江省乐清市柳市镇柳青路1号(德力西大厦 另设分支机构经营场所 乐清市柳市镇站东路155号)
生产企业名称 及生产地址	德力西集团有限公司 浙江省乐清市柳市镇站东路155号
产品名称和系列、 规格、型号	电动机综合保护器 JD-6,JD-6Q,JD-6A,JD-6S; 具体参数和型号解释详见附件
产品标准和技术要求	GB/T 14048.4-2020
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

谢肇煦

中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2003010309095685

Valid from: Jan.10,2022

Valid until: Jul.28,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	DELIXI Group Co., Ltd. (Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	DELIXI Group Co., Ltd. (Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China
NAME AND LOCATION OF THE FACTORY	DELIXI Group Co., Ltd. No.155 Zhandong Road, Liushi Town, Yueqing City, Wenzhou, Zhejiang Province, P.R.China
PRODUCT NAME, MODEL AND SPECIFICATION	Comprehensive protector for motors JD-6,JD-6Q,JD-6A,JD-6S ; See the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.4-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

C(2) 0134119

产品认证证书

II型自愿认证

证书编号: CQC2003010309095685

第 1 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

JD-6, JD-6Q, JD-6A, JD-6S

Uimp: 2.5kV; Ui: 380V; Ue: AC380V;

Ie: 63A ~ 150A, 100A ~ 250A, 63A ~ 400A, 200A ~ 500A,

30A ~ 150A, 80A ~ 400A (JD-6); 10A ~ 80A, 63A ~ 160A,

1A ~ 100A, 100A ~ 400A, 400A ~ 800A (JD-6Q);

20A ~ 400A (JD-6A); 63A ~ 200A (JD-6S);


脱扣级别: 10A; 极数: 3P;

防护等级: IP50 (接线端子除外);

配用的辅助触头 (1NO1NC):

Ith: 3A; AC-15; Ue: AC220V / Ie: 0.47A.

型号的解释:



型号	额定控制电源电压 Us	报警型式	主负载电流 A
JD-6	AC380V AC220V	指示灯	63 ~ 150
			100 ~ 250
			63 ~ 400
			200 ~ 500
			30 ~ 150
80 ~ 400			
JD-6A	AC380V、AC220V	指示灯	20 ~ 400
JD-6S	AC380V、AC220V	数字显示	63 ~ 200



中国质量认证中心

产品认证证书

II型自愿认证

证书编号：CQC2003010309095685

第 2 页 共 2 页

本证书及附件应同时使用，信息查验说明见证书页

纸号：

JD-6Q	AC380V AC220V	数字显示	10~80 63~160 1~100 100~400 400~800
-------	------------------	------	--



中国质量认证中心