



产品认证证书

证书编号：CQC2003010308040517

申请人名称及地址

德力西集团有限公司
浙江省乐清市柳市镇柳青路1号(德力西大厦)

制造商名称及地址

德力西集团有限公司
浙江省乐清市柳市镇柳青路1号(德力西大厦)

生产企业名称及地址

德力西集团有限公司(V025650)
浙江省乐清市柳市镇大桥路165号

产品名称和系列、规格、型号

刀型触头熔断器

熔断体型号：RT16-1(NT1),RT16i-1,RT16A-1(NTA1); 熔断体的额定电压 Un：AC500V/AC690V/DC440V；熔断体的额定电流 In：80,100,125,160,200,224,250A；额定短路能力 I1：120kA/AC500V,50kA/AC690V,100kA/DC440V；分断范围和使用类别：gG；熔断器支持件型号：RT16-1(NT1),RT16i-1；熔断器支持件的额定电压 Un：AC500V,AC690V,DC440V；熔断器支持件的额定冲击耐受电压 Uimp：6kV；熔断器支持件的额定电流 In：250A；极数：1P

产品标准和技术要求

GB/T 13539.2-2015

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求，特发此证。

发证日期：2020年09月02日 有效期至：2024年12月23日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任：_____

陆杨



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0347733



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2003010308040517

NAME AND ADDRESS OF THE APPLICANT

Delixi Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Delixi Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Delixi Group Co., Ltd. (V025650)
No.165 Daqiao Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Low-voltage Fuse(Fuse-link with Knife Blade Contact)

Fuse-link: RT16-1(NT1),RT16i-1,RT16A-1(NTA1); Fuse-link Un: AC500V/AC690V/DC440V; Fuse-link In: 80,100,125,160,200,224,250A; Rated breaking capacity I1: 120kA/AC500V,50kA/AC690V,100kA/DC440V; Breaking Range and Utilization Category: gG; Fuse-holder: RT16-1(NT1),RT16i-1; Fuse-holder Un: AC500V,AC690V,DC440V; Fuse-holder Uimp: 6kV; Fuse-holder In: 250A; Poles: 1P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.2-2015

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Sep.02,2020

Valid until: Dec.23,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0347733