



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE210302007514

Product Terminal Blocks

Applicant Zhejiang Delixi Electrical Co.,Ltd.
NO.155, ZhanDong Road, Liushi Town, Yueqing City,
Zhejiang Province , P.R. China.

Type/Model UK 2P5JD,UK 3JD,UK 5JD,UK 6JD,UK 10JD,UK
16JD,UK 35JD;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-21D0109-S, the submitted sample(s) of the above item complies with:

EN 60947-7-2:2009

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Dec.29,2021

Valid until: Dec.29,2024

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

CE 0012706



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE210302007514

UK 2P5JD, UK 3JD, UK 5JD, UK 6JD, UK 10JD, UK 16JD, UK 35JD;

UK 2P5JD, UK 3JD, UK 5JD, UK 6JD, UK 10JD, UK 16JD:

Ui:800V; Ue:800V;


UK 35JD:

Ui:1000V; Ue:1000V;

Ie:24A, 24A, 32A, 41A, 57A, 76A, 125A;

Rated cross-section:

2.5mm², 2.5mm², 4mm², 6mm², 10mm², 16mm², 35mm².



CHINA QUALITY CERTIFICATION CENTRE

