



CHINA QUALITY CERTIFICATION CENTRE  
CERTIFICATE OF CONFORMITY

Certificate No.: CE200302006985

**Product** Fuse terminal blocks

**Applicant** Zhejiang Delixi Electrical Co.,Ltd.  
Xiangjinyang Village, Liushi Town , Yueqing City, Zhejiang  
Province , P.R.China

**Type/Model** CDUK-5HESI

**Technical data** Uimp:6kV; Ui:500V; Ue:500V; In:6.3A; Rated  
cross-section: 4 square mm

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-20D0122-S, the submitted sample(s) of the above item complies with:

**EN60947-1:2007+A1:2011+ AMD2:2014, EN 60947-7-3:2009**

and fulfills testing requirements of the European Directive:

**Low Voltage Directive (LVD): 2014/35/EU**

**Valid from:** Oct.29,2020

**Valid until:** Oct.29,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>