



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200302006986

Product Switch type terminal blocks

Applicant Zhejiang Delixi Electrical Co.,Ltd.
Xiangjinyang Village, Liushi Town , Yueqing City, Zhejiang
Province , P.R.China

Type/Model CDUK-6S

Technical data Ui:500V; Ue:500V; Ie:41A; Rated cross-section: 6 square
mm; Service life in number of cycles: 100; Ith:41A,
longitudinal disconnection

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-20D0123-S, the submitted sample(s) of the above item complies with:
EN 60947-7-1:2009 in conjunction with EN 60947-1:2007, AMD1:2011, AMD2:2014
and fulfills testing requirements of the European Directive:
Low Voltage Directive (LVD): 2014/35/EU

Valid from: Oct.29,2020

Valid until: Oct.29,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010876