



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200302006994

Product

Terminal Blocks

Applicant

Zhejiang Delixi Electrical Co.,Ltd.

Xiangjinyang Village, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

CDUK-1.5N, CDUK-2.5N, CDUK-3N, CDUK-5N,
CDUK-6N, CDUK-10N, CDUK-16N, CDUK-35N,
CDUK-50N, CDUK-95N, CDUK-K3, CDUK-K5

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-20D0115-S, the submitted sample(s) of the above item complies with:

EN 60947-7-1:2009; EN60947-1:2007+A1:2011+A2:2014

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

Valid from: Nov.02,2020

Valid until: Nov.02,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE200302006994

CDUK-1.5N,CDUK-2.5N,CDUK-3N,CDUK-5N,CDUK-6N,CDUK-10N,
CDUK-16N,CDUK-35N,CDUK-50N,CDUK-95N,CDUK-K3,CDUK-K5

CDUK-1.5N:

Ui:500V;

Ue: 500V;

Ie:17.5A;

Rated cross-section:1.5mm²;

CDUK-2.5N,CDUK-3N,CDUK-5N,CDUK-6N,CDUK-10N,CDUK-16N:

Ui:800V;

Ue: 800V;

Ie: 24A,24A,32A,41A,57A,76A;

Rated cross-section: 2.5mm²,2.5mm²,4mm²,6mm²,10mm²,16mm²;

CDUK-35N,CDUK-50N,CDUK-95N:

Ui:1000V;

Ue: 1000V;

Ie: 125A,150A,232A;

Rated cross-section: 35mm²,50mm²,95mm²;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE200302006994

CDUK-K3,CDUK-K5:

Ui:500V;

Ue: 500V;

Ie: 24A,32A;

Rated cross-section: 2.5mm²,4mm²

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>