



产品认证证书

证书编号: CQC18012205011

发证日期: 2021年08月03日

有效期至: 2023年10月30日

委托人名称	德力西集团有限公司
及注册地址	浙江省乐清市柳市镇柳青路1号(德力西大厦,另设分支机构经营场所:乐清市柳市镇站东路155号)
制造商名称	德力西集团有限公司
及注册地址	浙江省乐清市柳市镇柳青路1号(德力西大厦,另设分支机构经营场所:乐清市柳市镇站东路155号)
生产企业名称	德力西集团有限公司
及生产地址	浙江省乐清市柳市镇站东路155号
产品名称和系列、规格、型号	10kV一体化柱上变台用低压熔断体 CDNT3J, CDNT3JA; Un:AC 400V; In:315A、630A; I1:50kA; 分断范围和使用类别:gJ
产品标准和技术要求	CQC1314-2017;GB/T 13539.1-2015;GB/T 13539.2-2015
认证模式	型式试验+获证后监督

上述产品符合 CQC13-462296-2017 认证规则的要求,特发此证。
本证书为变更证书,证书首次颁发日期:2018年10月30日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



签发: 谢肇煦



中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC18012205011

Valid from: Aug.03,2021

Valid until: Oct.30,2023

NAME AND REGISTERED ADDRESS OF THE APPLICANT	DELIXI Group Co., Ltd. No. 1 Liuqing Road, Liushi Town, Yueqing City, Zhejiang Province, P. R. China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	DELIXI Group Co., Ltd. No. 1 Liuqing Road, Liushi Town, Yueqing City, Zhejiang Province, P. R. China
NAME AND LOCATION OF THE FACTORY	DELIXI Group Co., Ltd. No. 155 Zhandong Road, Liushi Town, Yueqing City, Zhejiang Province, P. R. China
PRODUCT NAME, MODEL AND SPECIFICATION	Low-voltage fuse-link for 10kV Concrete Poles transformer platform Integrated CDNT3J , CDNT3JA ; Un:AC 400V ; In:315A、 630A ; I1:50kA ; Breaking Range and Utilization Category:gJ
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	CQC1314-2017;GB/T 13539.1-2015;GB/T 13539.2-2015
TYPE OF CERTIFICATION SCHEMES	type test+follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC13-462296-2017.

Date of original issued: Oct.30,2018

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE