



产品认证证书

证书编号: CQC2016010308898271

申请人名称及地址

德力西集团有限公司
浙江省乐清市柳市镇柳青路1号(德力西大厦)

制造商名称及地址

德力西集团有限公司
浙江省乐清市柳市镇柳青路1号(德力西大厦)

生产企业名称及地址

德力西集团有限公司(V025650)
浙江省乐清市柳市镇大桥路165号

产品名称和系列、规格、型号

刀型触头熔断器

RT16-3B(NT3B); Un:AC400V/690V;In:800A;I1:100kA/AC400V,50kA/AC690V;分断范围和使用类别:gG

产品标准和技术要求

GB/T 13539.2-2015

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求,特发此证。

发证日期: 2020年09月02日 有效期至: 2021年08月31日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: 陆杨



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0357213



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2016010308898271

NAME AND ADDRESS OF THE APPLICANT

DELIXI Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

DELIXI Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

DELIXI Group Co., Ltd. (V025650)
No.165 Daqiao Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-holder for Fuse-link with Knife-blade Contact
RT16-3B(NT3B); Un:AC400V/690V;In:800A;I1:100kA/AC400V,50kA/AC690V;Breaking Range and Utilization
Category:gG

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.2-2015

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Sep.02,2020

Valid until: Aug.31,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0357213