

产品认证证书

II型自愿认证

证书编号：CQC21107303089

发证日期：2021年07月20日

有效期至：2031年07月20日

委托人名称 及注册地址	德力西集团有限公司 浙江省乐清市柳市镇柳青路1号(德力西大厦另设分支机构经营场所：乐清市柳市镇站东路155号)
制造商名称 及注册地址	德力西集团有限公司 浙江省乐清市柳市镇柳青路1号(德力西大厦另设分支机构经营场所：乐清市柳市镇站东路155号)
生产企业名称 及生产地址	德力西集团有限公司 乐清市柳市镇站东路155号
产品名称和系列、 规格、型号	电动式隔离开关熔断器组 CDH15D-800、CDH15D-1000、CDH15D-1250； U_i :1000V； U_{imp} :12kV； U_e : AC400V、690V； I_{th} ：相极：800A、1000A、1250A，中性极：400A、500A、630A； I_e ：AC400V(CDH15D-800：800A；CDH15D-1000：1000A；CDH15D-1250：1250A)，AC690V(CDH15D-800：630A；CDH15D-1000：630A；CDH15D-1250：800A)；中性极：AC400V/630A，AC690V/400A； I_q ：50kA；使用类别：AC-23B；极数：3P、3P+N（N极可开闭）；配用的辅助触头：使用类别：AC-15； U_e ：AC380V； I_e ：1A； U_i ：500V； U_{imp} ：2.5kV； I_{th} ：6A；1NO1NC
产品标准和技术要求	GB/T 14048.3-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求，特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

谢肇煦



中国质量认证中心

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC21107303089

Valid from: Jul.20,2021

Valid until: Jul.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	DELIXI Group Co., Ltd. No .1 Liuqing Road, Liuzhen, Yueqing City, Zhejiang Province (Delixi Building has another branch business place :NO.155 ZhanDong Road, Liushi Town, Yueqing City)
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	DELIXI Group Co., Ltd. No .1 Liuqing Road, Liuzhen, Yueqing City, Zhejiang Province (Delixi Building has another branch business place :NO.155 ZhanDong Road, Liushi Town, Yueqing City)
NAME AND LOCATION OF THE FACTORY	DELIXI Group Co., Ltd. NO.155 Zhandong Road, Liushi Town, Yueqing City
PRODUCT NAME, MODEL AND SPECIFICATION	Fuse group of electric disconnecter CDH15D-800、CDH15D-1000、CDH15D-1250 ; Ui:1000V ; Uimp:12kV ; Ue: AC400V、690V ; Ith : Phase pole : 800A、1000A、1250A , neutral pole :400A、500A、630A ;Ie : AC400V(CDH15D-800 : 800A ; CDH15D-1000 : 1000A ; CDH15D-1250 : 1250A) , AC690V(CDH15D-800 : 630A ; CDH15D-1000 : 630A ; CDH15D-1250 : 800A) ; Neutral pole : AC400V/630A , AC690V/400A ; Iq : 50kA ; Utilization Category : AC-23B ; Poles : 3P、3P+N (Switched neutral pole) ; Attached Auxiliary Contact : Utilization Category : AC-15 ; Ue : AC380V ;Ie : 1A ; Ui : 500V ; Uimp : 2.5kV ; Ith : 6A ; 1NO1NC
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.3-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE