



中国国家强制性产品认证证书

证书编号：2024010302643277

认证委托人名称及地址

德力西集团有限公司

浙江省乐清市柳市镇柳青路1号(德力西大厦，另设分支机构经营场所：乐清市柳市镇站东路155号)

生产者名称及地址

德力西集团有限公司

浙江省乐清市柳市镇柳青路1号(德力西大厦，另设分支机构经营场所：乐清市柳市镇站东路155号)

生产企业名称及地址

德力西集团有限公司

乐清市柳市镇站东路155号

产品名称和系列、型号、规格

刀形隔离器

H□□-3000、H□□-2500 Ue: AC400V/690V; Ie: 3000A、2500A; Ui: 800V; Uimp: 12kV; Ith: 3000A; Icw: 40kA/1s; 使用类别: AC-20A; 极数: 3P、4P

产品标准和技术要求

GB/T 14048.3-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求，特发此证。

发证日期：2024年06月17日 有效期至：2029年06月16日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010302643277

证书附页：第 1 页 共 1 页

型号的解释：

$\frac{H}{(1)}$ $\frac{\square}{(2)}$ $\frac{\square}{(3)}$ - $\frac{\square}{(4)}$ / $\frac{\square}{(5)}$ $\frac{\square}{(6)}$

- (1) 刀形隔离器
- (2) “D”表示单投，“S”表示双投
- (3) 设计代号：“13”表示中央正面杠杆操作机构式；“13BX”表示中央正面旋转操作机构式；“13iBX”表示“13BX”的派生型号
- (4) 额定工作电流
- (5) 极数，“3”表示3极，“4”表示4极
- (6) “0”表示不带灭弧室，“1”表示带灭弧室

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302643277

NAME AND ADDRESS OF THE APPLICANT

DELIXI Group Co., Ltd.

No.1 Liuqing Road, Liuzhen, Yueqing City, Zhejiang Province.P.R.China (Delixi Building, Another branch business place :155 zhandong Road, Liushi Town, Yueqing City,Zhejiang Province, P.R.China)

NAME AND ADDRESS OF THE MANUFACTURER

DELIXI Group Co., Ltd.

No.1 Liuqing Road, Liuzhen, Yueqing City, Zhejiang Province.P.R.China (Delixi Building, Another branch business place :155 zhandong Road, Liushi Town, Yueqing City,Zhejiang Province, P.R.China)

NAME AND LOCATION OF THE FACTORY

DELIXI Group Co., Ltd.

NO.155 Zhandong Road, Liushi Town, Yueqing City

PRODUCT NAME,MODEL AND SPECIFICATION

Knife-disconnector

H□□-3000、H□□-2500 Ue : AC400V/690V ; Ie : 3000A、2500A ; Ui : 800V ; Uimp : 12kV ; Ith : 3000A ; Icw : 40kA/1s ; Utilization Category : AC-20A ; Poles : 3P、4P

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.17,2024

Valid until: Jun.16,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010302643277

Appendix : Page 1 of 1

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

H □ □ - □ / □ □
(1) (2) (3) (4) (5) (6)

- (1) 刀形隔离器
- (2) “D”表示单投，“S”表示双投
- (3) 设计代号：“13”表示中央正面杠杆操作机构式；“13BX”表示中央正面旋转操作机构式；
“13iBX”表示“13BX”的派生型号
- (4) 额定工作电流
- (5) 极数，“3”表示3极，“4”表示4极
- (6) “0”表示不带灭弧室，“1”表示带灭弧室

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.