



中国认可
国际互认
检测
TESTING
CNASL1145

检测报告

Test Report

产品名称: 万能式断路器
Name of Products: _____
产品型号: CDWNE-3200
Type: _____
委托方: 德力西电气有限公司
Client: _____
检测类别: 委托检测
Kind of Test: _____

上海电器设备检测所有限公司

SHANGHAI TESTING & INSPECTION INSTITUTE FOR
ELECTRICAL EQUIPMENT CO. LTD.



产品名称	万能式断路器			商 标	/	
型 号	CDWNE-3200					
技术参数	#01: CDWNE-3200 拧紧力矩:95N.m					
检测类别	委托检测					
委托人	德力西电气有限公司			地 址	上海市嘉定区江桥镇爱特路 188 号 6 号楼	
生产者	德力西电气有限公司			地 址	上海市嘉定区江桥镇爱特路 188 号 6 号楼	
送样数量	1	送样者	/		产品编号	/
抽样地点	/	抽样者	/		抽样数量/ 抽样基数	/
抽样日期	/ 年 / 月 / 日			到样日期	2024 年 10 月 14 日	
样品编号	#01					
检测依据	GB/T 14048.3-2017《低压开关设备和控制设备 第 3 部分: 开关、隔离器、隔离开关及熔断器组合电器》, GB/T 20645-2021《特殊环境条件 高原用低压电器技术要求》及委托方要求					
判定依据	GB/T 14048.3-2017《低压开关设备和控制设备 第 3 部分: 开关、隔离器、隔离开关及熔断器组合电器》, GB/T 20645-2021《特殊环境条件 高原用低压电器技术要求》及委托方要求					
检测日期	2024 年 10 月 14 日~2024 年 10 月 15 日					
检测结论	试验项目 1 (见检验项目汇总表), 符合要求。 签发日期 2024 年 10 月 19 日 检验检测专用章					
备注						

批准 小敏清

审核 高旭帆

编制 于子豪

样品照片



CDWNE-3200

检测

测 试 照 片



条 款	检测项目及检验要求	测量或观察结果	判 定
		#01	
GB/T 14048.3-2017 GB/T 20645-2021 及委托方要求	产品名称: 万能式断路器 型号规格: CDWNE-3200 序号1 机械寿命 环境温度: -45℃ 操作次数: 100 次 操作频率: 10 次/h 试后样品无明显损伤, 且可以正常动作	-46.0 100 10 符合要求	符合要求

-以下空白-



声 明

STATEMENT

1. 本报告（包括复制件）未加盖印章一律无效。

The test report (including its copy) without the seal shall be considered as invalid.

2. 本报告未经本实验室书面批准，不得部分复制，除非全部复制。

The test report shall not be reproduced except in full, without written approval of the laboratory.

3. 本报告无编制、审核、批准人签字无效。

The test report without the signature of the preparing person, review person and approval person shall be considered as invalid.

4. 本报告涂改无效。

Any corrections made on any parts of this test report shall be considered as invalid.

5. 检测结果只与委托检测的委托方送样样品有关。

This result is only related to the samples delivered.

6. 本机构在资质认定证书确定的能力范围内，对社会出具具有证明作用的数据、结果时，应标注检验检测资质认定标志，并加盖检验检测专用章。在资质认定证书确定的能力范围外，出具的检验检测报告或者证书上不得标注检验检测资质认定标志，该数据、结果对社会不具有证明作用。

When the laboratory issues data and results that prove the role within the scope of the qualifications determined by the qualification certificate, it shall mark the qualification certificate mark of the inspection and testing institution, and affix a special seal for inspection and testing. When the laboratory is outside the scope of the ability to determine the qualification certificate, the inspection and testing report or certificate issued shall not be marked with the qualification certificate of the inspection and testing institution. The data and results have no proof role of society.

检测单位/Testing
Laboratory:

上海电器设备检测所有限公司
Shanghai Testing & Inspection Institute for Electrical Equipment Co., Ltd.

地址/ Address:

上海市普陀区武宁路 505 号 / No.505, Wuning Road, Putuo District, Shanghai, China;
上海市奉贤区环城北路 358 号/No.358, Huancheng North Road, Fengxian District, Shanghai, China

邮编/ Postcode:

200063; 201401

电话/ Tel:

13402023395（刘丽丽）；13761673638（董慧）（业务接待/ Reception）
021-62574990-279（财务/ Financial）

邮箱/email:

liulili325@seari.com.cn;
donghui@seari.com.cn

投诉热线/tel/fax:

021-62574990-442 / 021-62435543

投诉邮箱/email:

stiee_customer@seari.com.cn