

报告编号: Reference No.:

22ZAS01P04D31-09938







检测报告

Test Report

产品名称:	框架断路器
Name of Products:	
产品型号:	CDW6i-2500AF, CDW6i-4000AF
Type:	
委托方:	德力西电气有限公司
Client:	
检测类别:	委托检测
Kind of Test:	

上海电器设备检测所有限公司

SHANGHAI TESTING & INSPECTIONINSTITUTE FOR ELECTRICAL EQUIPMENT CO. LTD.

报告编号: <u>22ZAS01P04D31-09938</u> 第 1 页 共 10 页

产品名称	框架断路器			商	标		/
型号		6i-2500AF, C	DW6i-4	4000AF			
技术参数	/						
检测类别			委托检	测			
委托人	德力西电气	有限公司	地	址	上海市嘉	定区	江桥镇爱特路 188 号 6 号楼
生产者	德力西电气有限公司			址	上海市嘉	定区	江桥镇爱特路 188 号 6 号楼
送样数量	2台	送样者	/		产品编	号	/
抽样地点	/	抽样者	/		抽样数抽样基		/
抽样日期	/ 年 / 月] / 日	到样	日期	20	022 £	羊 11 月 25 日
样品编号			#01~#	02			
检测依据	GB/T 14048.2-202	0《低压开关	设备和控制设	设备 第	2部分:]	新路	器》及委托方要求
判定依据	GB/T 14048.2-202	0《低压开关	设备和控制设	设备 第	2 部分: 1	新路	器》及委托方要求
检测日期	2	023 年 01 丿	月10日~	2023 年	F01月	11 E	∃
检测结论		试验项目 0	1~02 (检验项	目汇总			
					签发日	期	2023年01月30日
备注							

批准(小城清

审核 侧核

编制赵廷珞

第 2 页 共 10 页

	检测项目汇总表		
序号	检测项目	依据标准条 款	判定
01	脱扣极限和特性 (#01: CDW6i-2500AF In:630A Ue:AC1140V 3P 拧紧力矩: 50N·m)	8.3.3.2 及 委托方要求	合格
02	脱扣极限和特性 (#02: CDW6i-4000AF In:630A Ue:AC1140V 3P 拧紧力矩: 50N·m)	8.3.3.2 及 委托方要求	合格
	以下空白		

 条 款 检验项目及检验要求	判定
程序 I 一般特性 产品名称: 框架断路器 型 号 规 格 : CDW6i-2500AF In:630A Ue:AC1140V 3P 拧紧力矩: 50N·m	기 샤
产品名称: 框架断路器型 号 规 格 : CDW6i-2500AF In:630A Ue:AC1140V 3P 拧紧力矩: 50N·m	
型 号 规 格 : CDW6i-2500AF In:630A Ue:AC1140V 3P 拧紧力矩: 50N·m	
1 ht. 2 T	
8.3.3.2 及 脱扣极限和特性	合格
委托方要求 短路条件下的断开	
8.3.3.2.2 及 瞬时脱扣器	
委托方要求 周围空气温度: -45±2℃ -45	
单极通电 L1 L2 L3	
整定电流: Iimin =2In A	
(1) 试验电流: 0.9×Iimin A 1.13×10 ³	
不脱扣时间: ≥0.2s >0.2 >0.2 >0.2	
(2) 试验电流: 1.1×Iimin A 1.39×10 ³	
脱扣时间: < 0.2s 39ms 40ms 45ms	
37113 40113 43113	

 条 款 检验项目及检验要求 #01 定时限脱扣器 周围空气温度: -45 ± 2℃ 单极通电 性
定时限脱扣器 周围空气温度: -45±2℃ -45 单极通电 L1 L2 L3 整定值: Isdmin =1.5I _R A(I _R =0.4In) tsdmin =0.1s (1) 试验电流: 0.9×Isdmin A 341 不脱扣时间: ≥2×tsdmin s >0.2 >0.2 >0.2
周围空气温度: -45±2℃ 単极通电 整 定 值: Isdmin =1.5I _R A(I _R =0.4In) tsdmin =0.1s (1) 试验电流: 0.9×Isdmin A 不脱扣时间: ≥2×tsdmin s
单极通电 整定值: Isdmin =1.5I _R A(I _R =0.4In) tsdmin =0.1s (1) 试验电流: 0.9 × Isdmin A 不脱扣时间: ≥2 × tsdmin s
整定值: Isdmin =1.5I _R A(I _R =0.4In) tsdmin =0.1s (1) 试验电流: 0.9 × Isdmin A 341 不脱扣时间: ≥2 × tsdmin s >0.2 >0.2 >0.2
=0.1s (1) 试验电流: 0.9 × Isdmin A 341 不脱扣时间: ≥2 × tsdmin s >0.2 >0.2 >0.2
(1) 试验电流: 0.9 × Isdmin A 341 不脱扣时间: ≥2 × tsdmin s >0.2 >0.2 >0.2
不脱扣时间: ≥2×tsdmin s >0.2 >0.2 >0.2
(2) 试验电流: 1.1×Isdmin A 416 416
脱扣时间: <2 × tsdmin s 33ms 35ms 34ms
任选一极通电 L1
整定值: Isdmin =1.5I _R A(I _R =0.4In) tsdmin =0.1s
不脱扣持续时间: ≥0.06s >0.06
可返回电流: 0.4In A 252
可返回时间: ≥2 × tsdmin s >0.2

STIEE

检 测 报 告

报告编号: <u>22ZAS01P04D31-09938</u> 第 5 页 共 10 页

_	T	I	
<i>Q</i> ±4	ᄊᇌᇫᄑᄆᄑᄾᇪᇒᆂᆠ	测量或观察结果	和中
条 款	检验项目及检验要求	#01	判定
	过载条件下的断开		
b)及	反时限脱扣器		
委托方要求	周围空气温度: -45±2℃	-45	
	三极同时通电	L1L2L3	
	整定值: I _R min =0.4In A t _R min =1 s		
	(1) 试验电流: 1.05 × I _R min A	265	
	不脱扣时间: ≥2h	>2	
	(2) 试验电流: 1.30×I _R min A	328	
	脱扣时间: <2h	22s	
	(3) 试验电流: 2.00 × I _R min A	505	
	脱扣时间: 9±10% s	9	

报告编号: <u>22ZAS01P04D31-09938</u> 第 6 页 共 10 页

		泂	刂量或观察结	果	
条	次		#01		判定
	接地条件下的断开 周围空气温度: -45±2℃		-45		
	单极通电	L1	L2	L3	
	整定值: Igmin =0.2 × 630A tgmin =0.1s (1) 试验电流: 0.9 × Igmin A		114		
	不脱扣时间: ≥2×tgmin s	>0.2	>0.2	>0.2	
	(2) 试验电流: 1.1×Igmin A		139		
	脱扣时间: 80-120ms	117	112	118	

报告编号: <u>22ZAS01P04D31-09938</u> 第 7 页 共 10 页

	14-4	沙	测量或观察结:	 果	
条款	检验项目及检验要求		#02		判定
	程序【一般特性				
	产品名称: 框架断路器				
	型 号 规 格 : CDW6i-4000AF In:630A Ue:AC1140V 3P 拧紧力矩: 50N·m				
	序号2				
8.3.3.2 及	脱扣极限和特性				合格
	短路条件下的断开				
	瞬时脱扣器				
委托方要求	周围空气温度: -45±2℃		-45		
	单极通电	L1	L2	L3	
	整定电流: Iimin =2In A				
	(1) 试验电流: 0.9×Iimin A		1.13×10^{3}		
	不脱扣时间: ≥0.2s	>0.2	>0.2	>0.2	
	(2) 试验电流: 1.1×Iimin A		1.39×10^{3}		
	脱扣时间: < 0.2s	33ms	34ms	32ms	

	T				
条款	检验项目及检验要求	沙	量或观察结	果	判定
宋			#02		刊化
	定时限脱扣器				
	周围空气温度: -45±2℃		-45		
	单极通电	L1	L2	L3	
	整定值: Isdmin=1.5I _R A(I _R =0.4In) tsdmin=0.1s	S			
	(1) 试验电流: 0.9×Isdmin A		342		
	不脱扣时间: ≥2×tsdmin s	>0.2	>0.2	>0.2	
	(2) 试验电流: 1.1×Isdmin A		413		
	脱扣时间: <2×tsdmin s	39ms	41ms	46ms	
	任选一极通电		L1		
	整定值: Isdmin=1.5I _R A(I _R =0.4In) tsdmin=0.1s	3			
	(1) 试验电流: 1.5×Isdmin A		1.42×10^3		
	脱扣时间: 60-140ms		92ms		
	(2) 试验电流: 1.5×Isdmin A		1.42×10^3		
	不脱扣持续时间: ≥0.06s		>0.06		
	可返回电流: 0.4In A		253		
	可返回时间: ≥2×tsdmin s		>0.2		

STIEE 检测报告

		测量或观察结果	
条款	检验项目及检验要求	#02	判定
8.3.3.2.3	过载条件下的断开		
b)及	反时限脱扣器		
委托方要求	周围空气温度: -45 ± 2℃	-45	
	三极同时通电	L1L2L3	
	整定值: I _R min =0.4In A t _R min =1 s		
	(1) 试验电流: 1.05×I _R min A	265	
	不脱扣时间: ≥2h	>2	
	(2) 试验电流: 1.30×I _R min A	329	
	脱扣时间: <2h	24s	
	(3) 试验电流: 2.00 × I _R min A	506	
	脱扣时间: 9±10% s	9	

ST	Ί	F	F
$oldsymbol{\circ}$			

		沙	量或观察结	果	
条款	检验项目及检验要求		#02		判定
	Live 1 to 1 th or 11 the st				
	接地条件下的断开 周围空气温度: -45±2℃		-45		
	单极通电	L1	-43 L2	L3	
	整定值: Igmin =0.2 × 630A tgmin =0.1s	Li	1.2	L 3	
	(1) 试验电流: 0.9×Igmin A		115		
	不脱扣时间: ≥2×tgmin s	>0.2	>0.2	>0.2	
	(2) 试验电流: 1.1×Igmin A		139		
	脱扣时间: 80-120ms	109	117	117	

以下空白。

声明

STATEMENT

1. 本报告(包括复制件)未加盖印章一律无效。

The test report (including its copy) without the seal shall be considered as invalid.

2. 本报告未经本实验室书面批准,不得部分复制,除非全部复制。

The test report shall not be reproduced except in full, without written approval of the laboratory.

3. 本报告无编制、审核、批准人签字无效。

The test report without the signature of the preparing person, review person and approval person shall be considered as invalid.

4. 本报告涂改无效。

Any corrections made on any parts of this test report shall be considered as invalid.

5. 检测结果只与委托检测的委托方送样样品有关。

This result is only related to the samples delivered.

6. 本机构在资质认定证书确定的能力范围内,对社会出具具有证明作用的数据、结果时,应标注检验检测资质认定标志,并加盖检验检测专用章。在资质认定证书确定的能力范围外,出具的检验检测报告或者证书上不得标注检验检测资质认定标志,该数据、结果对社会不具有证明作用。

When the laboratory issues data and results that prove the role within the scope of the qualifications determined by the qualification certificate, it shall mark the qualification certificate mark of the inspection and testing institution, and affix a special seal for inspection and testing. When the laboratory is outside the scope of the ability to determine the qualification certificate, the inspection and testing report or certificate issued shall not be marked with the qualification certificate of the inspection and testing institution. The data and results have no proof role of society.

检测单位/Testing 上海电器设备检测所有限公司

Laboratory: Shanghai Testing & Inspection Institute for Electrical Equipment Co. Ltd.

地址/ Address: 上海武宁路 505 号 / 505 Wuning Road, Shanghai, P.R. China;

上海环城北路 358 号/358 North Huancheng Road, Shangghai, P.R. China

邮编/ Postcode: 200063; 201401

电话/Tel: 021-62574990-405 (业务接待/ Reception)

021-62574990-279 (财务/ Financial)

传真/Fax: 021-62545249 (业务接待/ Reception)

021-32255699 (财务/ Financial)

邮箱/email: epd@seari.com.cn

银行开户名/Bank 上海电器科学研究所(集团)有限公司 / Shanghai Electrical Apparatus

Account Name: Research Institute (Group) Co., Ltd

银行帐号/Bank 215080082110001

Account:

开户银行/Bank: 招商银行上海分行曹家渡支行 / China Merchants Bank Shanghai Branch

投诉热线/tel/fax: 021-62574990-442 / 021-62435543

投诉邮箱/email: stiee_customer@seari.com.cn